

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

**The Principal
Dogra Cultural & Educational Trust
National Highway, Kathua**

No: DFES-FP/9/2022-04(CC-7079422) 1481

Dated: 29.07.2024

Sub: Fire Safety Certificate.

Ref: Your online application submission dated: 07.06.2024 (PF012-5936528).

The spot inspection of above said Institute was got carried out by the inspecting officer of this department. During inspection, it was found that the management has installed 01 No. of Hose Reel Hose and 05 Nos. of First Aid Fire Extinguishers in their Institute premises. Besides this, one underground water storage tank is also available. The Institute is about 06 Km away from Fire and Emergency Station Kathua and is approachable for fire appliances in case of any emergency. Since the Institute is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety measures/ guidelines in letter and spirit forthwith:-

1. 03 Nos. of ABC Stored Pressure Type Fire Extinguisher of 04 Kg capacity each should be provided at strategic locations in the Institute building and 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exit/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmate during any emergency.
3. The Hose Reel Hose already existing should be enhanced immediately so that it cover the entire floor area of the institution in case of any emergency.
4. First Aid Firefighting system installed in the Institute building should be checked periodically. Staff and management should be fully trained in handling / operating of firefighting system installed in the Institute building.
5. All electric installations existing in the building should be concealed conduit type.
6. Manual Operated Electric Fire Alarm System should be installed in the building for alerting the inmates in case of any emergency.
7. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
8. The corridor of the building shall not be used for any kind of storage.
9. No Hazardous material should be kept inside of the Institute premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
10. The management of the Institute shall be wholly and solely responsible for keeping the firefighting system in working condition 24x7 and safe evacuation of its students during any mishap.
11. At present Dogra Cultural & Educational Trust is functioning in triple storied building. As such no addition / alteration should be made by the Institute management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/ cancelled.
12. The department can make a surprise visit to your Institute at any time. During the visit, if the firefighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
13. This clearance shall be subject to outcome of any dispute/investigation/enquiry/trial if any, pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued. Further, the status with regard to land shall be the responsibility of the concerned registering authority.
14. The instant clearance is strictly for adoption of fire safety measures/guidelines of the occupancy only and not for authentication of any other claim.
15. The validity of this clearance shall remain in force for one year and same needs to be renew yearly after inspection/checking of entire firefighting system (i.e. existing as well as proposed) installed in the school building. However, before granting permission/ recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


Director 29/07/2024

**Fire & Emergency Services, J&K
Jammu/Srinagar**